

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	31-07-2025 14:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	31-07-2025 14:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	90 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Communications
विभाग का नाम/Department Name	Department Of Telecommunications (dot)
संगठन का नाम/Organisation Name	Iti Limited
कार्यालय का नाम/Office Name	Iti Nsu Bengaluru
कुल मात्रा/Total Quantity	1
वस्तु श्रेणी /Item Category	Water Purification System with UV (Ultra-Violet Process) or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (Q2)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	2 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Exemption for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Exemption for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Certificate (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)

बिड विवरण/Bid Details	
बिड लगाने की समय-सीमा बढ़ाने के लिए आवश्यक न्यूनतम सहभागी विक्रेताओं की संख्या। / Minimum number of bids required to disable automatic bid extension	1
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
विगत प्रदर्शन / Past Performance	80 %
बिड से रिवर्स नीलामी सक्रिय किया/ Bid to RA enabled	No
बिड का प्रकार/ Type of Bid	Single Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय / Time allowed for Technical Clarifications during technical evaluation	3 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/ Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य / Estimated Bid Value	65000
मूल्यांकन पद्धति/ Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/ Arbitration Clause	No
सुलह खंड/ Mediation Clause	No

ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

विभाजन/Splitting

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	Yes
--	-----

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate. The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

3. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

4. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

6. Short Duration Bid has been published by the Buyer with the approval of the Competent authority due to Emergency procurement of critical products/services.

Water Purification System With UV (Ultra-Violet Process) Or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Construction	Aesthetically designed, water purification system having all the necessary components such as UV light and required filters, water tank as desired, suitable hot / cold / normal water dispensing arrangement, control system etc as applicable to provide safe drinking water as per IS 10500
Features and Performance	Method of Mounting	Countertop/Wall Mount/Freestanding
	Rate of Flow (In LPH) of purified water	25 and above, 50 and above
	Type of Water Purification Technology	Generally Conformity to IS 14724 for Ultraviolet (UV), Generally Conformity to IS 14724 for Ultraviolet (UV))+Ultrafiltration (UF)
	Guaranteed output water quality	As per IS 10500 or better,
Water Storage	Storage Tank (inclusive in the scope of supply)	Yes, No
Service, Warranty, Installation and Commissioning	Comprehensive warranty for complete unit	1 year from the date of satisfactory commissioning of the machine
	Number of Visits per Year	2 Nos.
	Installation and Commissioning inclusive in the scope of supply	Yes
	Training and Demonstration	The installation and demonstration of the machine at the consignee place shall be carried out as part of installation and commissioning
Certification / Test Report	Type of lab which carried out Test of Complete Product to prove the conformity of product as per Governing Specification	OEM, NABL Accredited Lab

Additional Specification Parameters - Water Purification System With UV (Ultra-Violet Process) Or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process) (1 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Purification Capacity Filter Cartridges	40 LPH Sediment, Carbon Block
Technology Type of Product	RO Water Purifier
Capacity Input Power	20 L 100-230 V AC
Warranty	1-year
• Commercial RO Water Purifier Ideal for Office Space • In built chiller with 20L storage capacity for steady supply	• High purification capacity of 40 L/hr • Max duty cycle per day – 200 LPD • Purification by RO+UF makes water 100 percent pure • TDS controller to maintain essential natural minerals in purified water • Durable stainless steel body

* Bidders offering must also comply with the additional specification parameters mentioned above.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Arvind Kumar	560016,ITI Limited, NSU,F-100, West wing, , Doorvaninagar, Bengaluru-560016,GST No-29AAACI4625C2ZU	1	15

Special terms and conditions-Version:1 effective from 12-12-2024 for category Water Purification System with UV (Ultra-Violet Process) or UV (Ultra-Violet Process)+UF (Ultra-Filtration Process)

1. Standard Terms and Conditions for Water Purification System UV or UV and UF

Scope of standard installation and commissioning for Water Purification System UV or UV and UF / Machine are as follows:

1. Sellers Responsibility:

- All the required tools and machinery as required for installation and commissioning of machine.
- Suitable hardware including brackets / screws washers etc., for mounting and fitting of machine at the respective locations.
- All the water connections / fittings piping shall be laid neatly, tidily, and securely as per best industry practices.
- They provide necessary piping and connections from inlet and outlet of the machine within 1~2 meters.
- All electrical wiring / connection to ensure proper functioning of the machine.
- All parts of the machine should be suitably earthed, and all electric wiring should be suitably insulated to avoid electric shock during usage.
- During Service visits with a Comprehensive Warranty / CMC the following shall be applicable.
 - Changing of Pre-Filter during each visit free of cost.
 - Cleaning of the complete water purifications system along with the water tank.
 - Changing of Complete Filters once a year free of cost which may including Sand Filter, Sediment Filter, Pre Carbon-Filter, Post Carbon Filter, Mineral Filter, Micron Filter, Anti-Sealant, Alkaline Filter, Mineralizer/Taste Enhancer Media, Activated Carbon Media, etc. (as applicable).
- Seller shall ensure that the " Actual Rate Rate of Flow (In LPH) of purified water" specified by them shall be in line with " Rate of Flow (In LPH) of purified wate".In case any contradiction is observed the superior value out of two shall reveal.

2. Buyers Responsibility:

1. To provide all gate passes for the installation team to access the area where installation to be carried out.
2. To provide suitable location for installation of machine which having required and easy access during installation and post installation maintenance. Any civil work shall be responsible of buyer.
3. To ensure inlet water supply within 1~2 meter of machine input and machine output.
4. To provide suitable power sockets within 1~2 meters of the machine.
5. To provide potable water of reasonable quality without having muddy appearance, solids and wastes etc. The input water is usually supplied from local municipalities or PHED supplies.
6. The Input water Head (pressure) shall be 0.3 kg (3-meter head).

3. Note to Sellers:

1. Seller may refer to GTC and ensure strict compliance of the uploaded/ offered product catalogue which shall be in line with their model having the claimed specifications in the catalogue or better.
2. Also, same model shall not be uploaded across catalogues with unreasonable/ contradictory offerings.
3. Sellers should ensure that offered product matches the CML specifications, including but not limited to LPH of water, if found to be contradictory suitable action as per IM policy will be initiated.
4. Sellers should note that while uploading the catalogue, all three images must be distinct.
 - **Image 1 - Should be Isometric View of the Complete Product**
 - **Image 2 - Front View of the Complete Product**
 - **Image 3 - LHS or RHS view of the Complete Product**
5. In case any discrepancy is observed in the offered/ uploaded products, OEM dashboard of the respective Brand may be removed, and account shall be suspended as per IM policy.

4. Note to Buyer:

1. For Procurement through BID/RA: - Buyers are advised to create bid with a specific value of Golden Parameter such as Type of Water Purification Technology, Filtration capacity (In LPH), Storage Tank (inclusive in the scope of supply), Storage Tank Material, Storage Tank Capacity (In Liter), Maximum Feed Water TDS (ppm) at which the machine LPH and Guaranteed output water quality is ensured, Guaranteed output water quality. Any bid created by the buyer without selecting specific LOV's or selecting Any Value in the above Golden Parameters will be treated as vague and is liable to be cancelled by competent authority at any point of time or if the above is resulting into limited competition or higher cost to the ex-chequer, the buyer will be solely responsible.
2. For Procurement through Direct Buy / L1 Procurement: - Buyers are advised to apply all filters and selections allowing all the values which are considered meeting or are better than their technical requirements. For example, Type of Controller if the requirement is Semi-Automatic, buyer should select other superior values i.e., Fully Automatic, such selection will act as Fully Automatic (in L1 buying). For any violation of the above resulting in limited competition or higher cost to the ex-chequer, the Buyer shall be solely.
3. Buyers should also refer to GTC Clause 4. xiii.(w). The ATC / additional specification if any added by the buyer shall not be contradictory to the GeM category specifications / technical parameters (TP). Bids with contradictory specifications and technical parameters will be treated as vague and is liable to be cancelled by competent authority at any point of time or if the above is resulting into limited competition or higher cost to the ex-chequer, the buyer will be solely responsible.
4. Buyer/ consignee shall verify all the technical parameters and specifications including Filtration capacity (In LPH), Type of Machine and other related parameters of the supplied and installed machine as per contract before issuing.
5. Buyers may consider EPBG for duration higher than machine warranty, which may be enched for inadequate warranty support.

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the

additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. **Generic**

1. The Seller shall not assign the Contract in whole or part without obtaining the prior written consent of buyer.
2. The Seller shall not sub-contract the Contract in whole or part to any entity without obtaining the prior written consent of buyer.
3. The Seller shall, notwithstanding the consent and assignment/sub-contract, remain jointly and severally liable and responsible to buyer together with the assignee/ sub-contractor, for and in respect of the due performance of the Contract and the Sellers obligations there under.

3. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

4. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

5. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

We need Commercial Water Purifier- RO+UF+TDS controlled with capacity of 20 litres per hour (LPH) and purification capacity of 40 LPH with below specifications.

1. Purification Capacity - 40 LPH
2. Filter Cartridges - Sediment, Carbon Block
3. Technology- RO
4. Type of Product- Water Purifier
5. Capacity -20 L
6. Input Power- 100-230 V AC
7. Warrnty- Minimum 1 Year.

- . * Commercial RO Water Purifier Ideal for Office Space.
- . * In built chiller with 20L storage capacity for steady supply
- . * High purification capacity of 40 L/hr
- . * Max duty cycle per day – 200 LPD
- . * Purification by RO+UF makes water 100 percent pure
- . * TDS controller to maintain essential natural minerals in purified water
- . * Durable stainless steel body.

All the terms mentioned in ATC, Bid document is mandatory.

Bidder has to seal and sign on each page of the Bid document and submit through GeM portal.

S

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---